

Eastlake Water Services
16720 S. Carlin Bay Rd
Harrison, ID 83833

Carlin Bay Property Owners
Water Report for March 2013

Operations

Plant operations have been within DEQ specifications for the month of March, there were no violations.

DEQ has changed our monitoring schedule of 2,4-D. The schedule has been modified from quarterly to annually as a result of no detection of 2,4-D since September 2010. This will result in a cost savings of \$585 per year (\$195 per test).

Water meters were read April 3rd. There were no water overages over 10,000 gallons per month.

Maintenance

The contract for Hach to calibrate our turbidity meters on a quarterly schedule was not renewed this year. Eastlake Water Services will resume calibrating these meters as they had done in previous years. Standards were ordered for calibration, 4-1 Liter bottles of Stabalcal 20NTU.

Actions needed by CBPOA

No actions required