

Eastlake Water Services
16720 S. Carlin Bay Rd
Harrison, ID 83833

Carlin Bay Property Owners
Water Report for XXX 20XX

Operations

Plant operations have been within DEQ specifications for the month of March, there were no violations.

DEQ has scheduled our Five Year Sanitary Survey for June 22nd. The last survey was conducted on July 21, 2009 and found to be in compliance. There were minor deficiencies that were noted and addressed. Deficiencies that are ongoing are reservoir roofs being sealed to prevent contamination, and a cross connection control program which was implemented.

Terry and I have been attending a Consumer Confidence Reporting Class that is conducted by our local Department of Environmental Quality.

Maintenance

Repair of the reservoir 1 top sealant should occur within the next 30 days. Hometown concrete will be visiting within the next few days to provide a bid for sealing the clear well top and schedule repair of reservoir 1 top. Reservoir 1 repair is under warranty.

The air gap drain from the pump to waste line to the water plant lagoon is leaking and needs to be repaired. I will be calling R.C. Worst for a cost estimate.

Terry and I will be conducting a walk through looking for potential problems prior to the Sanitary Survey.

Actions needed by CBPOA

A reminder that the Board needs to notify water customers who have a backflow device installed that they are required to have that device inspected yearly by a certified backflow specialist and provide documentation to CBPOA that the device was inspected so we can keep it on file per DEQ requirements.

Note to BOD that all cross connection documents/files are maintained and kept with Eastlake Water Services for the purpose of protecting our water system from contaminants.

Approval of the air gap repair upon being advised of cost.