

Eastlake Water Services
16720 S. Carlin Bay Rd
Harrison, ID 83833

Carlin Bay Property Owners
Water Report for September 2012

Operations

Plant operation was within DEQ specifications for the month of September, there were no violations.

Maintenance

Uninterruptible Power Supply (UPS) Battery was replaced.

Actions needed by CBPOA

No actions required